



Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 1 of 8

I. PWS INFORMATION: Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #:	2316000	City / Town:	WEBSTER
PWS Name:	WEBSTER WATER DEPARTMENT		PWS Class: COM <input type="checkbox"/> NTNC <input type="checkbox"/> TNC <input type="checkbox"/>

MassDEP Location (LOC) ID#	MassDEP Location Name	Sample Information		Date Collected	Collected By
MULT 2	MEMORIAL BEACH WTP	<input checked="" type="checkbox"/> (M)ultiple <input type="checkbox"/> (S)ingle	<input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (F)inished	07/30/21	SAS
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:			
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample	<input type="checkbox"/> Reanalysis	<input type="checkbox"/> Report Correction	
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #:	M-MA086	Primary Lab Name:	Alpha Analytical Labs	Subcontracted? (Y/N)	Y
----------------------	---------	-------------------	-----------------------	----------------------	---

Analysis Lab Cert. #:	M-MA030	Analysis Lab Name:	Alpha Analytical Labs
-----------------------	---------	--------------------	-----------------------

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:
--

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#		
537.1	08/09/21	08/09/21	1	Primary Lab:	L2141278-01	
				Subcontracted Lab:	L2141278-01	

CAS#	REGULATED PFAS CONTAMINANTS	Result ¹ ng/L	Result ² Qualifier	MCL [*] ng/L	MDL ng/L	MRL ng/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	2.74		0.619	0.619	1.85
335-67-1	Perfluorooctanoic Acid (PFOA)	3.56			0.619	1.85
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	0.778	J		0.619	1.85
375-95-1	Perfluorononanoic Acid (PFNA)	0.853	J		0.619	1.85
375-85-9	Perfluorohexanoic Acid (PFHpA)	1.30	J		0.619	1.85
335-76-2	Perfluorodecanoic acid (PFDA)	ND			0.619	1.85
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)		= 6.30	--	20	-	-
	UNREGULATED PFAS CONTAMINANTS					
375-73-5	Perfluorobutane sulfonic acid (PFBS)	1.37	J	0.619	0.619	1.85
307-55-1	Perfluorododecanoic acid (PFDoA)	ND			0.619	1.85
307-24-4	Perfluorohexanoic acid (PFHxA)	2.00			0.619	1.85
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND			0.619	1.85
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND			0.619	1.85
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND			0.619	1.85
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			0.619	1.85
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			0.619	1.85
763051-92-9	11-chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND			0.619	1.85
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	ND			0.619	1.85
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND			0.619	1.85
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND			0.619	1.85

¹ A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.² All qualifiers must be described under Lab Analysis Comments on page 2.



Per- and Polyfluoroalkyl Substances (PFAS) Report

PWS ID#: 2316000

Lab Sample ID#:

Primary Lab:

L2141278-01

Subcontracted Lab:

L2141278-01

Surrogate Name	% Recovery (70 – 130%)	Alternate Surrogate (must document reason for change)
¹³ C ₂ -PFHxA	91	
¹³ C ₂ -PFDA	116	
d ₅ -NEtFOSAA	108	
¹³ C ₃ -HFPO-DA	86	

Note: $^{13}\text{C}_3$ -HFPO-DA is not required for EPA Method 537 v1.1.

In addition to the SUR above you must attach the results of the ongoing QC results as specified by the method for the sample's extraction batch.

Laboratory analytical report with QC attached (check one item below).

All associated QC criteria reported within control limits including Lab Reagent/Method Blank (LRB), Field Reagent Blank (FRB), Surrogate Standards (SUR), Laboratory Fortified Blank (LFB), Matrix Spike/Duplicate (LFSM/LFSMD or FD) and RPD.

All associated sample and/or QC batch criteria not met. See Lab Analysis Comments below and narrative in attached report.

Lab Analysis Comments: (include sample/method parameters outside of or affecting QC controls/limits and result qualifiers)

Result Qualifier	Qualifier Description
J	The target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit.
Other Analysis Comments:	

* MCL or proposed MCL

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature:

Joseph L. Winkler

Date: 8/16/2021

8/16/2021

If not submitting these results electronically, mail TWO copies of this report to your MassDEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner. Note that during the Massachusetts COVID-19 state of emergency, in addition to submitting by mail reports may be emailed to program.director-dwp@mass.gov.

MassDEP REVIEW STATUS (Initial & Date)	Review Comments	<input type="checkbox"/> WQTS Data Entered
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved		



Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 3 of 8

I. PWS INFORMATION: Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #:	2316000	City / Town:	WEBSTER		
PWS Name:	WEBSTER WATER DEPARTMENT		PWS Class: COM <input type="checkbox"/> NTNC <input type="checkbox"/> TNC <input type="checkbox"/>		
MassDEP Location (LOC) ID#	MassDEP Location Name		Sample Information		Date Collected
MULT 2	MEMORIAL BEACH WTP FB		<input checked="" type="checkbox"/> (M)ultiple <input type="checkbox"/> (S)ingle	<input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (F)inished	07/30/21
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below: (1) Reason for Resubmission (2) Collection Date of Original Sample			
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction			
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #:	M-MA086	Primary Lab Name:	Alpha Analytical Labs		Subcontracted? (Y/N)	Y
Analysis Lab Cert. #:	M-MA030	Analysis Lab Name:	Alpha Analytical Labs			
If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:						

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#			
537.1	08/09/21	08/09/21	1	Primary Lab:	L2141278-02		
				Subcontracted Lab:	L2141278-02		

CAS#	REGULATED PFAS CONTAMINANTS	Result ¹ ng/L	Result ² Qualifier	MCL* ng/L	MDL ng/L	MRL ng/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	ND		0.605	1.81	
335-67-1	Perfluorooctanoic Acid (PFOA)	ND			1.81	
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	ND			1.81	
375-95-1	Perfluorononanoic Acid (PFNA)	ND			1.81	
375-85-9	Perfluorohexanoic Acid (PFHpA)	ND			1.81	
335-76-2	Perfluorodecanoic acid (PFDA)	ND			1.81	
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)		=	--	20	-	-
	UNREGULATED PFAS CONTAMINANTS					
375-73-5	Perfluorobutane sulfonic acid (PFBS)	ND		0.605	1.81	
307-55-1	Perfluorododecanoic acid (PFDoA)	ND			1.81	
307-24-4	Perfluorohexanoic acid (PFHxA)	ND			1.81	
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND			1.81	
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND			1.81	
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND			1.81	
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			1.81	
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			1.81	
763051-92-9	11-chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	ND			1.81	
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9CI-PF3ONS)	ND			1.81	
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND			1.81	
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND			1.81	

¹ A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.² All qualifiers must be described under Lab Analysis Comments on page 2.



Per- and Polyfluoroalkyl Substances (PFAS) Report

PWS ID#: 2316000

Lab Sample ID#:

Primary Lab:

L2141278-02

Subcontracted Lab:

L2141278-02

Surrogate Name	% Recovery (70 – 130%)	Alternate Surrogate (must document reason for change)
¹³ C ₂ -PFHxA	86	
¹³ C ₂ -PFDA	108	
d ₅ -NEtFOSAA	91	
¹³ C ₃ -HFPO-DA	85	

Note: ¹³C₃-HFPO-DA is not required for EPA Method 537 v1.1

In addition to the SUR above you must attach the results of the ongoing QC results as specified by the method for the sample's extraction batch.

Laboratory analytical report with QC attached (check one item below).

All associated QC criteria reported within control limits including Lab Reagent/Method Blank (LRB), Field Reagent Blank (FRB), Surrogate Standards (SUR), Laboratory Fortified Blank (LFB), Matrix Spike/Duplicate (LFSM/LFSMD or FD) and RPD.

All associated sample and/or QC batch criteria not met. See Lab Analysis Comments below and narrative in attached report.

Lab Analysis Comments: (include sample/method parameters outside of or affecting QC controls/limits and result qualifiers)

Result Qualifier	Qualifier Description
J	The target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit.
Other Analysis Comments:	

* MCL or proposed MCL

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature:

Joseph L. Womak

Date: 8/16/2021

8/16/2021

If not submitting these results electronically, mail TWO copies of this report to your MassDEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner. Note that during the Massachusetts COVID-19 state of emergency, in addition to submitting by mail reports may be emailed to program.director-dwp@mass.gov.

MassDEP REVIEW STATUS (Initial & Date)	Review Comments	<input type="checkbox"/> WQTS Data Entered
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved		

**Per- and Polyfluoroalkyl Substances (PFAS) Report**

Page 5 of 8

I. PWS INFORMATION: Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #:	2316000	City / Town:	WEBSTER
PWS Name:	WEBSTER WATER DEPARTMENT	PWS Class:	COM <input type="checkbox"/> NTNC <input type="checkbox"/> TNC <input type="checkbox"/>

MassDEP Location (LOC) ID#	MassDEP Location Name	Sample Information		Date Collected	Collected By
03G	BIGALOW RD	<input type="checkbox"/> (M)ultiple <input checked="" type="checkbox"/> (S)ingle	<input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (F)inished	07/30/21	SAS
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:			
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample	<input type="checkbox"/> Reanalysis	<input type="checkbox"/> Report Correction	
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #:	M-MA086	Primary Lab Name:	Alpha Analytical Labs	Subcontracted? (Y/N)	Y
----------------------	---------	-------------------	-----------------------	----------------------	---

Analysis Lab Cert. #:	M-MA030	Analysis Lab Name:	Alpha Analytical Labs
-----------------------	---------	--------------------	-----------------------

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#		
537.1	08/09/21	08/09/21	1	Primary Lab:	L2141278-03	
				Subcontracted Lab:	L2141278-03	

CAS#	REGULATED PFAS CONTAMINANTS	Result ¹ ng/L	Result ² Qualifier	MCL* ng/L	MDL ng/L	MRL ng/L	
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	6.08	J	0.615	0.615	1.84	
335-67-1	Perfluorooctanoic Acid (PFOA)	8.73			0.615	1.84	
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	1.99			0.615	1.84	
375-95-1	Perfluorononanoic Acid (PFNA)	0.736			0.615	1.84	
375-85-9	Perfluorohexanoic Acid (PFHpA)	3.57			0.615	1.84	
335-76-2	Perfluorodecanoic acid (PFDA)	ND			0.615	1.84	
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)				= 20.4	--	20	
UNREGULATED PFAS CONTAMINANTS							
375-73-5	Perfluorobutane sulfonic acid (PFBS)	2.21		0.615	0.615	1.84	
307-55-1	Perfluorododecanoic acid (PFDoA)	ND			0.615	1.84	
307-24-4	Perfluorohexanoic acid (PFHxA)	3.64			0.615	1.84	
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND			0.615	1.84	
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND			0.615	1.84	
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND			0.615	1.84	
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			0.615	1.84	
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			0.615	1.84	
763051-92-9	11-chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	ND			0.615	1.84	
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9CI-PF3ONS)	ND			0.615	1.84	
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND			0.615	1.84	
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND			0.615	1.84	

¹ A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.

² All qualifiers must be described under Lab Analysis Comments on page 2.



Per- and Polyfluoroalkyl Substances (PFAS) Report

PWS ID#: 2316000

Lab Sample ID#:

Primary Lab:	L2141278-03
Subcontracted Lab:	L2141278-03

Surrogate Name	% Recovery (70 – 130%)	Alternate Surrogate (must document reason for change)
¹³ C ₂ -PFHxA	90	
¹³ C ₂ -PFDA	105	
d ₅ -NEtFOSAA	104	
¹³ C ₃ -HFPO-DA	83	

Note: $^{13}\text{C}_3$ -HFPO-DA is not required for EPA Method 537 v1.1.

In addition to the SUR above you must attach the results of the ongoing QC results as specified by the method for the sample's extraction batch.

Laboratory analytical report with QC attached (check one item below).

All associated QC criteria reported within control limits including Lab Reagent/Method Blank (LRB), Field Reagent Blank (FRB), Surrogate Standards (SUR), Laboratory Fortified Blank (LFB), Matrix Spike/Duplicate (LFSM/LFSMD or FD) and RPD.

All associated sample and/or QC batch criteria not met. See Lab Analysis Comments below and narrative in attached report.

Lab Analysis Comments: (include sample/method parameters outside of or affecting QC controls/limits and result qualifiers)

Result Qualifier	Qualifier Description
J	The target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit.
Other Analysis Comments:	

* MCL or proposed MCL

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: *Donald Winkler*

Date: 8/16/2021

8/16/2021

If not submitting these results electronically, mail TWO copies of this report to your MassDEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner. Note that during the Massachusetts COVID-19 state of emergency, in addition to submitting by mail reports may be emailed to program.director-dwp@mass.gov.

MassDEP REVIEW STATUS (Initial & Date)		Review Comments	<input type="checkbox"/> WQTS Data Entered
<input type="checkbox"/> Accepted	_____	<input type="checkbox"/> Disapproved	

**Per- and Polyfluoroalkyl Substances (PFAS) Report**

Page 7 of 8

I. PWS INFORMATION: Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #:	2316000	City / Town:	WEBSTER
PWS Name:	WEBSTER WATER DEPARTMENT	PWS Class:	COM <input type="checkbox"/> NTNC <input type="checkbox"/> TNC <input type="checkbox"/>

MassDEP Location (LOC) ID#	MassDEP Location Name	Sample Information		Date Collected	Collected By
03G	BIGALOW RD FB	<input type="checkbox"/> (M)ultiple <input checked="" type="checkbox"/> (S)ingle	<input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (F)inished	07/30/21	SAS
Routine or Special Sample	Original, Resubmitted or Confirmation Report	(1) Reason for Resubmission		(2) Collection Date of Original Sample	
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample	<input type="checkbox"/> Reanalysis	<input type="checkbox"/> Report Correction	
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #:	M-MA086	Primary Lab Name:	Alpha Analytical Labs	Subcontracted? (Y/N)	Y
----------------------	---------	-------------------	-----------------------	----------------------	---

Analysis Lab Cert. #:	M-MA030	Analysis Lab Name:	Alpha Analytical Labs
-----------------------	---------	--------------------	-----------------------

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#		
537.1	08/09/21	08/09/21	1	Primary Lab:	L2141278-04	
				Subcontracted Lab:	L2141278-04	

CAS#	REGULATED PFAS CONTAMINANTS	Result ¹ ng/L	Result ² Qualifier	MCL* ng/L	MDL ng/L	MRL ng/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	ND		0.628	0.628	1.88
335-67-1	Perfluorooctanoic Acid (PFOA)	ND			0.628	1.88
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	ND			0.628	1.88
375-95-1	Perfluorononanoic Acid (PFNA)	ND			0.628	1.88
375-85-9	Perfluoroheptanoic Acid (PFHpA)	ND			0.628	1.88
335-76-2	Perfluorodecanoic acid (PFDA)	ND			0.628	1.88
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)		=	--	20	-	-
UNREGULATED PFAS CONTAMINANTS						
375-73-5	Perfluorobutane sulfonic acid (PFBS)	ND		0.628	0.628	1.88
307-55-1	Perfluorododecanoic acid (PFDoA)	ND			0.628	1.88
307-24-4	Perfluorohexanoic acid (PFHxA)	ND			0.628	1.88
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND			0.628	1.88
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND			0.628	1.88
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND			0.628	1.88
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			0.628	1.88
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			0.628	1.88
763051-92-9	11-chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	ND			0.628	1.88
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9CI-PF3ONS)	ND			0.628	1.88
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND			0.628	1.88
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND			0.628	1.88

¹ A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.

² All qualifiers must be described under Lab Analysis Comments on page 2.



Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 8 of 8

PWS ID#: 2316000

Lab Sample ID#:

Primary Lab:

L2141278-04

Subcontracted Lab:

L2141278-04

Surrogate Name	% Recovery (70 – 130%)	Alternate Surrogate (must document reason for change)
¹³ C ₂ -PFHxA	96	
¹³ C ₂ -PFDA	117	
d ₅ -NEtFOSAA	99	
¹³ C ₃ -HFPO-DA	91	

Note: $^{13}\text{C}_3$ -HFPO-DA is not required for EPA Method 537 v1.1

In addition to the SUR above you must attach the results of the ongoing QC results as specified by the method for the sample's extraction batch.

Laboratory analytical report with QC attached (check one item below).

All associated QC criteria reported within control limits including Lab Reagent/Method Blank (LRB), Field Reagent Blank (FRB), Surrogate Standards (SUR), Laboratory Fortified Blank (LFB), Matrix Spike/Duplicate (LFSM/LFSMD or FD) and RPD.

All associated sample and/or QC batch criteria not met. See Lab Analysis Comments below and narrative in attached report.

Lab Analysis Comments: (include sample/method parameters outside of or affecting QC controls/limits and result qualifiers)

Result Qualifier	Qualifier Description
J	The target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit.
Other Analysis Comments:	

* MCL or proposed MCL

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature:

Joseph Warkens

Date: 8/16/2021

If not submitting these results electronically, mail TWO copies of this report to your MassDEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner. Note that during the Massachusetts COVID-19 state of emergency, in addition to submitting by mail reports may be emailed to program.director-dwp@mass.gov.

MassDEP REVIEW STATUS (Initial & Date)	Review Comments	<input type="checkbox"/> WQTS Data Entered
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved		

CHAIN OF CUSTODY



WESTBORO, MA
TEL: 508-469-8220
FAX: 508-469-8193

Project Information

Project Name:

MANSFIELD, MA
TEL: 508-422-6300
FAX: 508-422-3268

Client Information

Client: TOWN OF WEBSTER
Address: 38 Hill St

Phone: (508) 949-3800 x 4016
Fax: (508) 949-3868

Email: TURTLE@WEBSTER.MA.GOV
 These samples have been previously analyzed by Alpha

Other Project Specific Requirements/Comments/Detection Limits:

Standard

RUSH (only confirmed if non-specific)

Date Due:

Time:

ALPHA Lab ID (Lab Use Only)

Sample ID	Collection Date	Sample Matrix	Sampler's Initials
41278-01	7/21/21	1:05 DW	SAS ✓
-03 03G	7/21/21	1:20 DW	SAS ✓

Report Information - Data Deliverables		Billing Information	
<input type="checkbox"/> Project #: <u>41278</u> <input type="checkbox"/> Same as Client Info <u>Ver.5.</u>		<input type="checkbox"/> PO #: <u>Ver.5.</u> <input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ADEx <input type="checkbox"/> Add'l Deliverables	
Regulatory Requirements/Report Limits			
<input type="checkbox"/> State/Fed Program <input type="checkbox"/> Criteria		<input type="checkbox"/> SAMPLE HANDLING Filtration _____ <input type="checkbox"/> Done <input type="checkbox"/> Not needed <input type="checkbox"/> Lab to do <input type="checkbox"/> Preservation <input type="checkbox"/> Lab to do <small>(Please specify below)</small>	
<input type="checkbox"/> Sample Specific Comments		ANALYSIS PFAs - 5371 Finished Water 2 Final Water 2	
PAGE <u>1</u> OF <u>1</u> Date Rec'd In Lab: <u>8/2/21</u>		Date Time <u>7/20/21 1:45 PM</u> Received By: <u>Thomas Gutierrez</u> Form No. 01-01 (rev. 14-OCT-07)	
Please print clearly, legibly and completely. Samples can not be logged in and turnaround times clock will not start until any ambiguities are resolved. All samples submitted are subject to Alpha's Terms and Conditions. See reverse side.			
Relinquished By: <u>Sammy</u> <u>Sammy</u> <u>Sammy</u> <u>Sammy</u>		Date/Time <u>8/2/21 11:45 AM</u> Received By: <u>Sammy Gutierrez</u> Form No. 01-01 (rev. 14-OCT-07)	
Relinquished By: <u>Sammy</u> <u>Sammy</u> <u>Sammy</u> <u>Sammy</u>		Date/Time <u>8/2/21 12:35 PM</u> Received By: <u>Sammy Gutierrez</u> Form No. 01-01 (rev. 14-OCT-07)	
Relinquished By: <u>Sammy</u> <u>Sammy</u> <u>Sammy</u> <u>Sammy</u>		Date/Time <u>8/2/21 1:25 PM</u> Received By: <u>Sammy Gutierrez</u> Form No. 01-01 (rev. 14-OCT-07)	