

## Site Plan Review



Architecture  
Engineering  
Planning  
Land Surveying  
Environmental  
Services

April 16, 2019

Webster Planning Board  
Webster Town Hall  
350 Main Street  
Webster, MA 01570  
*via e-mail*

RE: Long Subaru As-Built Plan Review

Board Members,

As requested, CME Associates, Inc. (CME) reviewed the following materials received on April 16, 2019:

Item 1            One (1) sheet plan entitled "As-Built Plan, 7 Sutton Road, Webster, Massachusetts, prepared for Howard Stein Hudson" prepared by WSP USA, Inc., dated December 17, 2018, and revised April 10, 2019.

Our January 7, 2019 review letter noted that approved hoods were missing from the catch basins on-site. The Eliminator hoods have now been installed on the existing catch basins to improve stormwater quality from the site. Our previous comments regarding the As-Built Plan have been addressed by recent revisions. The site as constructed appears to meet the intent of the approved plans.

Sincerely,

A handwritten signature in blue ink, appearing to read "Chuck Eaton", is written over a light blue horizontal line.

Chuck Eaton, P.E., LEED-AP  
Webster Town Engineer

*cc via email:* Ann Morgan, Webster Director of Planning & Economic Development  
Ted Tetreault, Webster Building Commissioner  
Scott Barry, Long Subaru

u:\muni\_ma\websterplanbd\2015700\_webster planning board\review letters\2019-04-16\_long-subaru\_as-built.docx